



中国认可
国际互认
检测
TESTING
CNAS L1020



实验室名称: 国家电器产品质量监督检验中心
Lab Name: China National Center for Quality Supervision
and Test of Electrical Apparatus Products

No 19N0315-S

检验 (试验) 报告 Test Report

委托单位: 江西变电设备有限公司
Client:

产品名称: 干式变压器
Name of Product:

产品型号: SCB13-2500/10
Product Type:

检验类别: 委托试验
Test Category:

本实验室对出具的检验 (试验) 结果负责, 未经实验室书面同意, 不得部分地复制本报告。


The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.

检测报告

编号: 19N0315-S

共 4 页 第 1 页

样品名称	干式变压器	规格型号	SCB13-2500/10
		商 标	/
抽(送)样单序号	/	样品数量	1 台
抽(送)样地点	国家电器产品质量监督检验中心	样品基数	/
抽(送)样日期	2019.06.23	样品等级	/
到样日期	2019.06.24	原编号或 生产日期	1900677
检测完成日期	2019.06.24		
检测依据	GB/T1094.1-2013《电力变压器 第1部分: 总则》 GB20052-2013《三相配电变压器能效限定值及能效等级》		
检测项目	空载损耗、负载损耗 (120℃)		
检 测 结 论	<p>对江西变电设备有限公司生产的 SCB13-2500/10 型号干式变压器的空载损耗和负载损耗 (120℃) 两个项目进行检测, 所检项目符合 GB/T1094.1-2013 和 GB20052-2013 的相关要求, 其能效等级为 1 级。</p> <p>(以下空白)</p>		



8111-JN001